



Approval of the Trademark Trevira CS®

Pierre Frey
47, rue des Petits Champs
75001 Paris
France

| | |
|--|--------------------|
| Application No.: | 220132.1 |
| Date of issue: | 08.09.2022 |
| Valid until: | 25.03.2027 |
| Article name: | F3570 LHOTSE |
| End use: | Drapes Curtains |
| Square weight (g/m²): | 56 |
| According to customer specification | |
| Composition of the raw materials: | Polyester 100% |
| Composition of the fabric: | Trevira CS 100% |

The article F3570 LHOTSE has been tested under the Trevira trademark application no. 220132 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH
(This document is valid without signature.)