



## Approval of the Trademark Trevira CS®

Pierre Frey  
47, rue des Petits Champs  
75001 Paris  
France

<b>Application No.:</b>	200626.2
<b>Date of issue:</b>	18.01.2021
<b>Valid until:</b>	01.10.2025
<b>Article name:</b>	F3055 Kaly
<b>End use:</b>	Drapes Curtains
<b>Square weight (g/m<sup>2</sup>):</b>	72
According to customer specification	
<b>Composition of the raw materials:</b>	Polyester 100%
<b>Composition of the fabric:</b>	Trevira CS 100%

The article F3055 Kaly has been tested under the Trevira trademark application no. 200626 and is granted approval for the trademark Trevira CS® for interior use.  
The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.  
The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.  
The article meets the requirements for class 1 according to EN 13773.  
This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.  
Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.  
Thus meets also the requirements according to British Standard BS 5867 part 2 type C.  
This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH  
(This document is valid without signature.)